

LINEMAN'S GLOVES TEST LOG

Hybrid Electric Vehicles

The employer shall certify that the electrical protective equipment has been tested in accordance with the requirements of OSHA 1910.137. Rubber insulating gloves must be electrically tested every 6 months once issued for use. Gloves may not be used unless they have been tested within the previous 12 months, even if they have been stored and not yet issued. They should also be tested by the tech before each use for any air leaks from pinholes, punctures or tears.

Date	Facility Name	Facility Address	Results	Manager's Signature